

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/14/2008
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 045209	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 02/13/2007
NAME OF PROVIDER OR SUPPLIER BYRD HAVEN NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 105 SO COLLEGE SEARCY, AR 72143	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	INITIAL COMMENTS	K 000		
K 067 SS=D	<p>The findings on this statement of deficiencies demonstrates non-compliance with Title 42, Code of Regulations 483.70(a), life safety from fire. The requirement is not met as evidenced by the facility's failure to meet the National Fire Protection Association code(s) cited.</p> <p>NFPA 101 LIFE SAFETY CODE STANDARD</p> <p>Heating, ventilating, and air conditioning comply with the provisions of section 9.2 and are installed in accordance with the manufacturer's specifications. 19.5.2.1, 9.2, NFPA 90A, 19.5.2.2</p> <p>This STANDARD is not met as evidenced by: Based on observation, the facility failed to ensure the air handler for the Central Hall shut down when the fire alarm was activated. This failed practice had the potential to affect 6 residents residing on the Central Hall according to the Roster Sample Matrix dated 2/12/07. The findings are:</p> <p>On 2/13/07 at 10:50 a.m., the Central Hall was used as return air plenum. The air handler for the Central Hall did not shut down when the fire alarm was activated.</p>	K 067		3/15/07
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE		TITLE		(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.